

McCordick, Connor

From: notification@civiclive.com
Sent: Wednesday, June 21, 2023 11:39 AM
To: McCordick, Connor
Subject: Planning Board Public Comment 2023-06-21 11:38 AM(EST) Submission Notification

Categories: To Do

Caution! This message was sent from outside your organization.

[Block sender](#)

Planning Board Public Comment 2023-06-21 11:38 AM(EST) was submitted by Guest on 6/21/2023 11:38:31 AM (GMT-05:00) US/Eastern

Name	Value
Project Name	13 Franklin St
Commenter Name	Dean Johnson
Address	360 Taunton Street
Contact Info	djohnson@wrentham.gov
Form Comment	- I question the current condition and kind of material for the water service and it being connected to an OLD 6" CIWM. I recommend the current service gets cut and capped off on the 6" CIWM. - I also recommend the new 2" domestic and 6" Fire Service connects onto the much larger and newer 16" CIWM.

To view this form submission online, please follow the link below:

<https://townofwrentham.hosted.civiclive.com/form/one.aspx?objectId=19627027&contextId=19414337&returnto=submissions>