

## McCordick, Connor

---

**From:** Antonioli, Brian  
**Sent:** Tuesday, May 16, 2023 10:54 AM  
**To:** McCordick, Connor; Johnson, Dean; Scotton, Robert; Naff, John; Maduskuie, Robert; Marino, Antonio; Luce, Darryl; Labonte, George; Sweet, Kevin; McGrath, William; Tanis, Matt  
**Cc:** Planning; Bugbee, Elizabeth  
**Subject:** RE: Requests for Comments - ZBA  
**Categories:** To Do

147 Arnold St – At this time, no comments based on the application.

**13 Franklin St** - Due to extent of work explained, current water service should be cut and capped at main. A new (larger?) domestic water service and separate fire sprinkler line should be tapped and installed off of the newer 16" water main.

- Increased drainage runoff into the parkland does raise some concern for flooding potential.  
What is the actual increase of stormwater runoff volume and rate?

205 Creek St - It is not clear to me on the plans provided with the application where exactly the current water service is in relation to the proposed addition.

- If the addition is going to be above the current water service, then the water service would have to be moved.
- If the water service needs to be moved it would need to be brought up to all current standard accepted by Wrentham Rules & Regulations.

Thanks,

Brian Antonioli  
Director of Public Works

Town of Wrentham  
Department of Public Works  
360 Taunton St., P.O. Box 658  
Tel: 508-384-5477  
Fax: 508-384-5481

**Effective immediately my new email is : [bantonioli@wrentham.gov](mailto:bantonioli@wrentham.gov)**

---

**From:** McCordick, Connor <CMcCordick@wrentham.gov>  
**Sent:** Thursday, May 04, 2023 10:28 AM  
**To:** Antonioli, Brian <bantonioli@wrentham.gov>; Johnson, Dean <djohnson@wrentham.gov>; Scotton, Robert <rscotton@wrentham.gov>; Naff, John <JNaff@wrentham.gov>; Maduskuie, Robert <RMaduskuie@fire.wrentham.ma.us>; Marino, Antonio <AMarino@fire.wrentham.ma.us>; Luce, Darryl <dLuce@wrentham.gov>; Labonte, George <Labonte@police.wrentham.ma.us>; Sweet, Kevin