RECEIVED 07/26/23 Planning Dept Exhibit # 9

## McCordick, Connor

From: notification@civiclive.com

Sent: Wednesday, July 26, 2023 1:08 PM

McCordick, Connor To:

**Subject:** Planning Board Public Comment 2023-07-26 01:08 PM(EST) Submission Notification

**Categories:** To Do

Caution! This message was sent from outside your organization.

Block sender

Planning Board Public Comment 2023-07-26 01:08 PM(EST) was submitted by Guest on 7/26/2023 1:08:10 PM (GMT-05:00) US/Eastern

Name Value

**Project Name** 10 Commerce Blvd - gas station

Commenter Name Dean Johnson

Address 360 Taunton Street

Contact Info djohnson@wrentham.gov

Please have the contractor follow the Standard Water System Requirements. How long is Form Comment the 2" water service? Water service over 150' (between curb stop and building) require a meter pit just after the curb stop. A 2" RPZ backflow device will need to be installed where service enters building. Please reach out with any questions.

To view this form submission online, please follow the link below:

https://townofwrentham.hosted.civiclive.com/form/one.aspx?objectId=19696029&contextId=19414337&return to=submissions