

McCordick, Connor

From: notification@civiclive.com
Sent: Wednesday, August 16, 2023 8:11 AM
To: McCordick, Connor
Subject: Planning Board Public Comment 2023-08-16 08:10 AM(EST) Submission Notification
Categories: To Do

Caution! This message was sent from outside your organization.[Block sender](#)

Planning Board Public Comment 2023-08-16 08:10 AM(EST) was submitted by Guest on 8/16/2023 8:10:57 AM (GMT-05:00) US/Eastern

Name	Value
Project Name	10 Commerce Blvd - gas station
Commenter Name	Brian Antonioli
Address	360 Taunton St
Contact Info	bantonioli@wrentham.gov
Form Comment	Based on currently submitted documents, if water service line is longer than 150' then a meter pit would be required. Required to follow Wrentham Rules & Regulations as would any and all projects. Thanks

To view this form submission online, please follow the link below:

<https://townofwrentham.hosted.civiclive.com/form/one.aspx?objectId=19736342&contextId=19414337&return to=submissions>